
RUNOUT AND LOAD



RELUBRICATION MAINTENANCE

The relubrication interval depends on the environment and the type of application. As standard the SKA RT bearing should be relubricated every 5000 hours of operation. The grease quantity (grams) is calculated by this formula: 3720 * X

Where X depending in which time the bearing reach 5000h of operation.

X weeks = 0.002 X months = 0.003 X annual = 0.004 X two-year or three-year = 0.005

In case of 8 hours of operation per day, we have: 3720 * 0.005 = 19 grams


Relubrication must be applied using one of the two M6 radial holes on the front flange. The holes are closed by grub screw.

The operator must remove the grain, and apply a M6 Grease nipple (not provided). Once the grease is applied, the grease nipple must be removed, and the hole must be close again with M6 grub screw.

FEEDBACK SPECIFICATIONS



Motor size		148	245	335	430		
Nominal voltage	Vdc	4 to 7					
Nominal current @5Vdc (without load)	mA	≤ 220					
Maximum frequency	kHz	400					
Output signal		Sine 1 Vpp					
Zero impulse	pulse/turn	1					
N° of periods per revolution	periods/rev	8192	16384	23040	32768		
Accuracy	arc sec	11	5,5	4	3		
Resolution	cpr	Function of interpolator					



5	
2	
2	

Motor size		148	245	335	430		
Nominal voltage	Vdc		3,6 to 14				
Nominal current @5Vdc	mA	300					
Maximum frequency	MHz	16					
Absolute interface		Endat 2.2 22					
Number of bits (singleturn)		22	23	23	24		
Absolute resolution per revolution	increments/rev	4.194.304	8.388.608	8.388.608	16.777.216		
Accuracy	arc sec	3	1,5	1	1		